

2019 Consumer Confidence Report

Water System Name: Nice Mutual Water Company

Report Date: May 4th 2020

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Lake / Surface Water

Name & general location of source(s): Clear Lake, Located in Lake County, California

Drinking Water Source Assessment information: Clear Lake is vulnerable to contamination from recreational use of the lake, accidents / spillages from Highway 20 and herbicide / pesticide runoff from agricultural sources.

A copy of our 2017 assessment can be obtained from our regional department of water resources drinking water division in Santa Rosa. Phone: 707-576-2145

Time and place of regularly scheduled board meetings for public participation: Board meetings are held at 3246 Lakeshore Blvd on the third Tuesday of every month at 7:00pm.

For more information, contact: David Fultz General Manager Phone: (707) 274-1149

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a mo.) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	8/2019	10	Non detect	.0	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/2019	10	.046	0	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/10/19	8.9		none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/10/19	105		none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Gross Alpha Particle (pCi/L)	4/19/17	.026		15	0	Decay of natural deposits.
TTHMs (Total Trihalomethanes) ppb	Tested 2019 Quarterly	86.7	32.1---86.7	80		Byproduct of drinking water chlorination.
Haa5's (Haloacetic Acids) ppb	Tested 2019 Quarterly	61.0	28.2---61.0	60		Byproduct of drinking water chlorination.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Specific Conductance (umhos/cm)	4/10/2019	230		1600		Substances that form ions when in water; seawater influence
Total Dissolved Solids (ppm)	4/10/2019	140		1000		Runoff/leaching from natural deposits
Sulfate (ppm)	4/10/2019	5.4		500		Runoff/leaching from natural deposits; industrial wastes
Chloride (ppm)	4/10/2019	5.0		500		Runoff/leaching from natural deposits; seawater influence

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Nice Mutual Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water

and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.

For Systems Providing Surface Water as a Source of Drinking Water

TABLE 6 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES	
Treatment Technique ^(a) (Type of approved filtration technology used)	#1 Multi-media pressure filtration #2 Ultra membrane filtration
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 - Be less than or equal to 0.3 NTU in 95% of measurements in a month. 2 - Not exceed 1.0 NTU for more than eight consecutive hours. 3 - Not exceed 2.0 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	100%
Highest single turbidity measurement during the year	.29
Number of violations of any surface water treatment requirements	0


(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Violation of a MCL

None

Water Treatment



U Y P Z F N R T O V Y L V G W B K W P K I U R H E K C
 W P J L E L J S A H C G L X K N S O J G T C M P S Q V
 U Z S C S O N C F I L T E R E F I U Q A O M P E I L X
 T Y X V D O O L F X L R R U T R A L N E V R P Y V E B
 Y T I D I B R U T L U G T O E D L N D R V R L H T D L
 L B E N I R O L H C P U B S S M C V F I C L J Y Z I A
 H S A W K C A B F T C A E L T Q P O L L U T A N T R O
 C F T E T P W P G O A R A A B I H R K I K F G V E O I
 R E G U X A G D Q U V V O K H E Y Q C R G O S M L U G
 E T B O L K S I S O M S O E Y C V X U L D A M R S L I
 T C L G O Z X T I P M X D X M E P S A R B J H M N F U
 A U E L S O J R E C M I R K C V K Y I C R B Q F F G Z
 W C S E X B L L X A D P C B M T U N H W T E N L P Q H
 X F J B W V C F J I T L U F S X K L R H E Z I V L L H
 O K Q E P E D L S G T U M U I I P J G H L E T G C O G
 W N T U L A P C Z M P M N J N A Z U N I D L S O D S H
 W Y L D S G O E C V Q B Q G I M O Q J L Q N Y X P W W
 B P Y V I L V X M T D I F L R R N E S I F N C N X N N
 K K G G O A R E T E I N T R D O I V D H A Y O U N Y U
 A J R E H N F C C B G S E P I U B W M G M R Z E V Q
 J H F M E T E R Q U T W Q I D L X N B L A D Q C X K Z
 X L W V Z N W Q X A I N Z F Z L S A D K F D Y R N B K
 H Y J E K I B X Y F P X A I M F O U Q W E W M X A E E
 Q N U W F A D C O X H V P R E L G A R X A Y S P N H O
 Z M S K D M L P J V F I V A U A M A U J M T T V F S Y
 L I P D M O U M W G V M O L D E M D C T C D E U C G N
 P U I V Y X S A W A W N W C B S A H W P U G M R U W N

ALGAE
 AQUIFER
 CLARIFIER
 DISCOLOR
 DRINKING
 DROUGHT
 FAUCET
 FLOOD
 FLUORIDE
 GROUNDWATER
 LAKE
 MYCROCYSTIN
 PLUMBING
 POLLUTANT
 RESERVOIR
 WATER
 MAIN
 METER
 VALVE
 BACKWASH
 CHLORINE
 FILTER
 OSMOSIS
 TURBIDITY